



**PERMIT TO CONSTRUCT  
Onsite Wastewater System**

File Nbr: **2019090019**  
County: Saluda

Name: AMERICAN LAND HOLDING LLC

Program Code: 360

Type Facility: HOUSE

Address: 59 MIDDLETON DR  
LUGOFF, SC 29078

System Code: 815

Subdivision: PALMETTO POINTE

Site: LOT 23

TM#:

Block: Lot: 23

, SC

Water Supply: PUBLIC

**PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS**

Daily Flow (gpd): 360

**Tank Sizes (gal):** Septic Tank: 1000

Pump Chamber: 1000

Grease Trap:

LTAR: .30

**Trenches:** Length (ft): 300

Width (in): 36

Max. Depth (in): 30

Agg. Depth (in):

Min Pump Capacity: 10

gpm at 20

ft. of Head

**SPECIAL INSTRUCTIONS/CONDITIONS**

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

See Attached Page...

**PERMIT TO CONSTRUCT SYSTEM DIAGRAM**

(NTS)

*system design by  
Land Resource Management soil  
classifier walker ferguson  
828-231-1663  
see Attached supplemental  
diagram*

Issued/Revised By: *[Signature]*

Date: 10/29/19



# APPLICATION SUPPLEMENTAL FORM

## Onsite Wastewater System

File Nbr: **2019090019**

County: **Saluda**

Name: **AMERICAN LAND HOLDING LLC**

Address:

**59 MIDDLETON DR  
LUGOFF, SC 29078**

Program Code: **360**

Type Facility: **HOUSE**

TM#:

Subdivision **PALMETTO POINTE**

Site: **LOT 23**

Water Supply: **PUBLIC**

Block:

Lot: **23**

**SC**



## LAND RESOURCE MANAGEMENT

Land Evaluation by Land Experts

### SYSTEM SPECIFICATIONS


Est. Daily Flow (in GPD) 360 LTAR 3 Tank Size (Gallons) 1000 Pump Chamber

Size (Gallons) 1000 Min. Pump Capacity      gpm @      feet of head ZSS (in inches)     

Water table encountered? Yes      No ✓

### Trenches

Total Number 5 Length (in feet) 300 Width (in inches) 36 Max. Depth (in inches) 30 aggregate  
mtl.      Aggregate Depth      Alternative product 5 mil. quicky infiltrator - 12"



Palmetto Pointe  
Lot # 23

K&M