



**PERMIT TO CONSTRUCT**  
**Onsite Wastewater System**

File Nbr: **2019090035**  
County: Saluda

Name: AMERICAN LAND HOLDINGS LLC

Type Facility: HOUSE

Subdivision: PALMETTO POINTE

Block: Lot: 95

Address: 59 MIDDLETON DR  
LUGOFF, SC 29078

Site: LOT 95  
, SC

Program Code: 362

System Code: 271

TM#:

Water Supply: PUBLIC

**PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS**

Daily Flow (gpd): 360

LTAR: .25

**Tank Sizes (gal):** Septic Tank: 1000 Pump Chamber: 1000

Grease Trap:

**Trenches:** Length (ft): 509 Width (in): 48 Max. Depth (in): 22

Agg. Depth (in): 9

Min Pump Capacity: 10 gpm at 20

ft. of Head

**SPECIAL INSTRUCTIONS/CONDITIONS**

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

See Attached Page...

**PERMIT TO CONSTRUCT SYSTEM DIAGRAM**

(NTS)

System design by  
Land Resource Management soil  
Classifier Walker Ferguson  
828-231-1663  
See Attached supplemental  
diagram

Issued/Revised By:

Date:

11/15/19



# APPLICATION SUPPLEMENTAL FORM

Onsite Wastewater System

File Nbr: **2019090035**

County: Saluda

Name: AMERICAN LAND HOLDINGS LLC

Address:

Program Code: 362

Type Facility: HOUSE

59 MIDDLETON DR

TM#:

LUGOFF, SC 29078

Subdivision PALMETTO POINTE

Site: LOT 95

Water Supply: PUBLIC

Block:

Lot: 95

SC



## LAND RESOURCE MANAGEMENT

Land Evaluation by Land Experts

### SYSTEM SPECIFICATIONS

Est. Daily Flow (in GPD) 300 LTAR 35 Tank Size (Gallons) 1200 Pump Chamber


Size (Gallons) 1000 Min. Pump Capacity      gpm @      feet of head ZSS (in inches)     

Water table encountered? Yes      No     

### Trenches

Total Number 7 Length (in feet) 509 Width (in inches) 48" Max. Depth (in inches) 22" aggregate

mtl. 100% Aggregate Depth 9 Alternative product     



*Handwritten signature*